

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7167-1062:114 Page 1 of 1

CATEGORY: Control Unit/Household

LISTEE: Detection Systems, Inc., 130 Perinton Parkway, Fairport, NY 14450
Contact: Frank Mioduszewski *(585) 223-4060

DESIGN: Model DS7400i and DS7400Xi residential fire alarm control units. Refer to listee's printed data sheet for additional detailed product description and operational considerations. System components:

DS7400i, DS7400Xi	Control Panel
DS7433	8-Zone Expansion Module
DS7445, DS7447, DS7448	Keypads
DS7420i	Fire Module
DS7416i, DS7416iF	Communication Module
DS7430, DS7432	Multiplex Expander Module
DS7460	2-Zone Expander
DS7481	Single Phone Line Monitor
DS7488	Relay Board
3100-0200	AAGARD Radio Interface Module
AE-TR-16	Transformer
DS9484	Remote NAC Expander
DS7430, DS7436	Multiplex Expander Module
DS7480	Bell Supervisory Board
DS7465	Input/Output Multiplex Module
DS7457	Single Zone Multiplex Inpput Module

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as residential fire alarm control units for use with separately listed compatible initiating and indicating devices.

This control unit can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1996 Edition. Refer to listee's Installation instructions Manual for details.

- NOTE:
1. Burglary and other non-fire functions were not examined.
 2. **Fire Alarm Verification Feature** (delay of fire alarm) shall not be used in California.

*Rev. 06-05-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 5, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**